



MIDWEST CANVAS CORP.

CONSTRUCTION PRODUCTS DIVISION

PHONE: 518 892 9992

dunphymidwest@gmail.com

FAX: 518 271 2536

October 2011

Dear Construction Products Customer;

This is to certify that all Midwest Canvas Corporation's insulating blankets have been tested for Effective Thermal Resistance using ASTM: C518 test method.

ASTM: C518 thermal resistance test
Calibrated test equipment:
Mitutoyo Calipers model#39247-35 ID MM160-008
Sartorius Balance model 1384 ID MM170-004
Thermometer range -10 to 260 C
Holometrix Heat Flow Meter mode Rapid K s# TCT-3
Tested with a 3-inch airspace
Product: MCF6.32 Effective R value: 6.32

Testing performed by: Orfield Laboratories, Minneapolis, Mn. Project number: 97-002.6 4/97

Tim Dunphy
National Sales Manager
Midwest Canvas Corp.

N.B.: PRICING SUBJECT TO CHANGE WITHOUT NOTICE.

